

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0028:164 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200

DESIGN: Model AFP-200 fire alarm control unit. Local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU). Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

4XTM	Transmitter Module
RTM-8	Relay Module
DP-AFP200, *ADP-4	Dress Panel
TR-4XG	Trim Ring
MMX-1, -101	Monitor Module
ISO-X	Loop Isolator Module
N-ELR	EOL Resistors
CRT-2	Terminal with Keyboard
VS4095/5	Printer
CMX-1	Control Module
BB-17	Battery Box
AVPS-24 *MPS-24A, -24B	Power Supply
NAM-232	Network Adapter Module
4XMM	Meter Module
*INA	Intelligent Network Annunciator
*CAB-A3, -B3, -C3, -D3	Series Enclosure
*ABS-4D, ABF-4	INA Cabinet
*AKS-1	Annunciator Key Switch
*MIB-W, -F, -WF	Media Interface Board

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Suitable for central station (PPU) service when used with separately listed compatible DACT. This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details. Also suitable for releasing service. For releasing application, Models NR-45 battery charger and AVPS-24 power supply shall not be used. Please contact the manufacturer for action.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 7, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager